



AC input side





























Features

- Auto ranging with ultra-wide charging voltage (10.5~21V, 21~42V, 42~80V, 54~100V; Please refer to page 8 for setting)
- · Built-in CANBus protocol for control, setting and monitoring
- Programmable 2/3 stage and charging curve via SBP-001
- Manual setting for 2/3 stage and 4 built-in charging curves via DIP S.W
- · Multiple protections:

Short circuit / Over voltage / Over temperature/ Battery under voltage /Battery reverse polarity (No damage)

- · Charger OK and Battery Full signal
- · Temperature compensation function to prolong battery life (Lead-acid only) · Equipments or instruments with back-up battery
- · -30°C ~+70°C wide operating temperature
- · Thermal controlled DC fan for noise reduction
- · Remote ON/OFF control
- · Smart programmer available (Order NO.: <u>SBP-001</u>, sold separately)
- · Carry handle accessory available(Order NO.: DS-Carry handle, sold separately)
- · Comply with 62368-1 + 60335-1/-2-29 dual certification
- · Suitable for lead-acid (Pb) and li-ion batteries
- · 3 years warranty

Applications


- · AGV
- · E-Bike, E-Scooter, Camping car, Bus, Specialty vehicles
- · Robotic lawn mower
- Washing robot
- · Recreation craft, Personal yacht or workboat
- · Surveillance system
- · Telecommunication base station
- · Radio system backup solution

GTIN CODE

MW Search: https://www.meanwell.com/serviceGTIN.aspx

Description

NPB-450 is a miniaturized, versatile, and ultra-wide voltage intelligent charger. It utilizes a fully digital control design with automatic battery voltage detection technology, with five key features including intelligent, versatile, user friendly, safe, and compact. The series have four models with output voltage ranges of 10.5~21V, 21~42V, 42~80V, and 54~100V respectively. The charging voltage range of each model is wide enough to cover a variety of different battery voltages and battery chemistries, and there is a built-in intelligent voltage detection charging mode (Note this mode is set to OFF by factory default and is suitable for lithium batteries with BMS only). The NPB-450 can pair with MEAN WELL's SBP-001 programmer for digital configuration, such as select 2/3 stage charging, adjust charging voltage/current, and set charging cycle time to protect battery lifetime. Through the user-friendly DIP S.W. on front panel, user may also directly adjust the 2/3 stage charging, current (50~100%), and select between the 4 types of preset charging curves. In addition, a CANBus communication protocol is built in to meet professional applications, which allows remote controlling and monitoring for the status of the charger. In terms of safety, it has intelligent detection for proper battery voltage and connection as well as protection from reverse polarity. It passes ITE IEC/EN/UL62368-1 and household appliances EN60335-1/-2-29 dual safety and 3-year warranty to guarantee reliable operation. The NPB-450 is truly an intelligent, safe, and reliable universal charger with outstanding cost performance.



Voltage stage whereas 125% of Vfloat over Float stage.

(as available on http://www.meanwell.com)

SPECIFICATION

MODEL NPB-450-24 NPB-450-48 NPB-450-72 NPB-450-12 BOOST CHARGE VOLTAGE(Vboost)(default) 14.4V 28.8V 57.6V 72V FLOAT CHARGE VOLTAGE(Vfloat)(default) | 13.8V 27.6V 55.2V 69V CHARGE VOLTAGE RANGE Note.3 21 ~ 42V 42 ~ 80V 54 ~ 100V 10.5 ~ 21V MAX. OUTPUT CURRENT(CC) Note.4 25A 13.5A 6.8A 5.5A OUTPUT MAX. POWER Note.4 420W 453.6W 456.96W 462W **RECOMMENDED BATTERY** 90 ~ 300AH 45 ~ 155AH 24 ~ 80AH 19 ~ 64AH CAPACITY (AMP HOURS) Note.5 **LEAKAGE CURRENT** <1mA FROM BATTERY (Typ.) **VOLTAGE RANGE** Note.6 90 ~ 264VAC 127 ~ 370VDC 47 ~ 63Hz **FREQUENCY RANGE** PF>0.98/115VAC, PF>0.95/230VAC at full load POWER FACTOR (Tvp.) INPUT EFFICIENCY (Typ.) Note.7 92% 93% 93% AC CURRENT (Typ.) 4 5A/115VAC 2 2A/230VAC INRUSH CURRENT (Typ.) COLD START 50A at 230VAC LEAKAGE CURRENT <0.75mA/240VAC SHORT CIRCUIT Protection type: Constant current limiting, charger will shutdown after 5 sec, re-power on to recover Note.8 21.5 ~ 26V 82 ~ 100V 102 ~ 120V **OVER VOLTAGE** Note.9 PROTECTION Protection type: Shut down and latch off o/p voltage, re-power on to recover Protected internal reverse detection, No damage, re-power on to recover after fault condition is removed REVERSE POLARITY Shut down O/P voltage, recovers automatically after temperature goes down OVER TEMPERATURE **CHARGING STAGE** 2 or 3 stage selectable through DIP S.W on panel, or SBP-001 with computer Programmable: Constant current(CC), Tapper current(TC), Constant voltage(CV) and Float voltage(FV) **CHARGING PARAMETERS** can be set through SBP-001 with computer **ADJUSTABLE** Manual setting: 4 built-in charging curves adjustable via DIP S.W on panel, Please refer to function manual for more detail **AUTO RANGING FOR** Please refer to functin manual for more detail (page 8) CHARGING (Typ.) Charging current adjustable 50~100% by via potentiometer on panel (Only for auto ranging mode) **FUNCTION CANBUS INTERFACE** ANBus 2.0B, Can control, Setting and monitoring(Vo,lo,charging curve, internal temp. and DC output ON/OFF) **CHARGER OK** The TTL signal out, Charger OK = $H(4.5 \sim 5.5V)$; Charger failure or protection status = $L(-0.5 \sim +0.5V)$ The TTL signal out, Battery full = $H(4.5 \sim 5.5 \text{V})$; Charging = $L(-0.5 \sim +0.5 \text{V})$ **BATTERY FULL SIGNAL** Short: Charger normal work Open: Charger stop charging REMOTE CONTROL TEMPERATURE COMPENSATION By external NTC Depends on internal temperature **FAN SPEED CONTROL** -30 ~ +70°C (Refer to "Derating Curve") WORKING TEMP. 20 ~ 95% RH non-condensing **WORKING HUMIDITY** ENVIRONMENT -40 ~ +85°C, 10 ~ 95% RH non-condensing STORAGE TEMP., HUMIDITY TEMP. COEFFICIENT ±0.05%/°C (0 ~ 50°C) VIBRATION 10 ~ 500Hz, 2G 10min./1cycle, 60min. each along X, Y, Z axes **SAFETY STANDARDS** CB IEC62368-1,IEC60335-1/2-29, Dekra BS EN/EN62368-1,BS EN/EN60335-1/2-29, UL62368-1, EAC TP TC 004 approved I/P-O/P:3KVAC I/P-FG:2KVAC O/P-FG:0.5KVAC WITHSTAND VOLTAGE ISOLATION RESISTANCE I/P-O/P, I/P-FG, O/P-FG:100M Ohms / 500VDC / 25°C / 70% RH Parameter Test Level / Note Conducted BS EN/EN55032 (CISPR32),BS EN/EN55014-1 Class B **EMC EMISSION** Radiated BS EN/EN55032 (CISPR32).BS EN/EN55014-1 Class B Harmonic Current BS EN/EN61000-3-2 Class A Voltage Flicker BS EN/EN61000-3-3 **SAFETY &** BS EN/EN61000-6-2 **EMC** (Note 10) Parameter Standard Test Level / Note **FSD** BS FN/FN61000-4-2 Level 3, 8KV air; Level 2, 4KV contact Radiated BS FN/FN61000-4-3 Level 2 3V/m EFT / Burst BS EN/EN61000-4-4 Level 2, 1KV **EMC IMMUNITY** Surge BS EN/EN61000-4-5 Level 2, 1KV/Line-Line, Level 3, 2KV/Line-Earth Conducted BS EN/EN61000-4-6 Level 2, 3Vrms Magnetic Field BS EN/EN61000-4-8 Level 1, 1A/m >95% dip 0.5 periods, 30% dip 25 periods, Voltage Dips and Interruptions BS EN/EN61000-4-11 >95% interruptions 250 periods MTRF Telcordia SR-332 (Bellcore); 83.4K hrs min. MIL-HDBK-217F (25°C) 821.0K hrs min. OTHERS DIMENSION 205*135*55mm (L*W*H) 1.02Kg; 8pcs/ 10Kg / 1.71CUFT **PACKING** 1. Modification for charger specification may be required for different battery specification. Please contact battery vendor and MEAN WELL for details. 2. All parameters NOT specially mentioned are measured at 230VAC input, rated load and 25°C of ambient temperature. 3. This is the range when programming Vboost or Vfloat by using SBP-001, the smart battery charging programmer. 4. Refer to derating curve. 5. This is MEAN WELL's suggested range. Please consult your battery manufacturer for their suggestions about maximum charging current limitation. 6. Derating may be needed under low input voltages. Please check the derating curve for more details 7. The efficiency is measured at 16.8V charge voltage(12V model), 33.6V charge voltage(24V model), 67.2V charge voltage(48V model), 84V charge voltage(72V model). NOTE 8. This protection mechanism is specified for the case the short circuit occurs after the charger is turned on. 9. Each model incorporates a MCU-controlled dynamic over voltage protection, which is about 125% of Vboost over Constant Current stage and Constant


10. The charger is considered a component which will be installed into a final equipment. The final equipment must be re-confirmed that it still meets EMC

11. The ambient temperature derating of 3.5°C/1000m with fanless models and of 5°C/1000m with fan models for operating altitude higher than 2000m(6500ft)

directives. For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies."

※ Product Liability Disclaimer: For detailed information, please refer to https://www.meanwell.com/serviceDisclaimer.aspx







■ Function Manual

1.Manual setting




1.1 2 or 3-stage selectable via DIP S.W on panel


S.W NO.	Function	Description
3.VV NO.	1 unction	Description
1	OFF: 3 stage(Default), ON: 2 stage	This series provides 2 or 3 stage charging curve
2	Charrier annua adinatable	Abuilt in abouting surrous adjustable via DID C W
3	Charging curve adjustable	4 built-in charging curves adjustable via DIP S.W

1.2 Charging curve can be adjustable via DIP S.W on panel

© 2 stage charging curve



O Default 3 stage	charging	curve
-------------------	----------	-------



State	NPB-450-12	NPB-450-24	NPB-450-48	NPB-450-72		
Constant Current	25A	13.5A	6.8A	5.5A		
Vboost	14.4V	28.8V	57.6V	72V		

State	NPB-450-12	NPB-450-24	NPB-450-48	NPB-450-72	
Constant Current 25A		13.5A	6.8A	5.5A	
Vboost	14.4V	28.8V	57.6V	72V	
Vfloat	13.8V	27.6V	55.2V	69V	

- © Suitable for lead-acid batteries (flooded, Gel and AGM) and Li-ion batteries (lithium iron and lithium manganese).
- © Suitable for lead-acid batteries (flooded, Gel and AGM) and Li-ion batteries (lithium iron and lithium manganese).
- * The default curve is programmable, whereas other pre-defined curves can be activated by the means of the DIP S.W; please refer to the table below and the Mechanical Specification.



© Embedded 2 stage charging curve

DIP SW position		12V model						
2	3	Description	CC(default)	Vboost				
OFF	OFF	Default, programmable		14.4				
ON	OFF	Pre-defined, gel battery	25A	14.0				
OFF	ON	Pre-defined, flooded battery	25A	14.2				
ON	ON	Pre-defined, AGM battery,LiFe04		14.6				
DIP SW	position	24V model						
2	3	Description	CC(default)	Vboost				
OFF	OFF	Default, programmable		28.8				
ON	OFF	Pre-defined, gel battery	13.5A	28.0				
OFF	ON	Pre-defined, flooded battery	13.5A	28.4				
ON	ON	Pre-defined, AGM battery,LiFe04		29.2				
DIP SW	position	48V model						
2	3	Description	CC(default)	Vboost				
OFF	OFF	Default, programmable		57.6				
ON	OFF	Pre-defined, gel battery	6.8A	56.0				
OFF	ON	Pre-defined, flooded battery	0.0A	56.8				
ON	ON	Pre-defined, AGM battery,LiFe04		58.4				
DIP SW	position	72V model						
2	3	Description	CC(default)	Vboost				
OFF	OFF	Default, programmable		72				
ON	OFF	Pre-defined, gel battery	5.5A	70				
OFF	ON	Pre-defined, flooded battery	J.JA	71				
ON	ON	Pre-defined, AGM battery,LiFe04		73				

© Embedded 3 stage charging curve

DIP SW position		12V model						
2	3	Description	CC(default)	Vboost	Vfloat			
OFF	OFF	Default, programmable		14.4	13.8			
ON	OFF	Pre-defined, gel battery	25A	14.0	13.6			
OFF	ON	Pre-defined, flooded battery	ZSA	14.2	13.4			
ON	ON	Pre-defined, AGM battery,LiFe04		14.6	14.0			
DIP SW	position	24V mo	del					
2	3	Description	CC(default)	Vboost	Vfloat			
OFF	OFF	Default, programmable		28.8	27.6			
ON	OFF	Pre-defined, gel battery	13.5A	28.0	27.2			
OFF	ON	Pre-defined, flooded battery	13.5A	28.4	26.8			
ON	ON	Pre-defined, AGM battery,LiFe04		29.2	28.0			
DIP SW	position	48V model						
2	3	Description	CC(default)	Vboost	Vfloat			
OFF	OFF	Default, programmable		57.6	55.2			
ON	OFF	Pre-defined, gel battery	6.8A	56.0	54.4			
OFF	ON	Pre-defined, flooded battery	0.0A	56.8	53.6			
ON	ON	Pre-defined, AGM battery,LiFe04		58.4	56.0			
DIP SW position		72V mo	odel					
2	3	Description	CC(default)	Vboost	Vfloat			
OFF	OFF	Default, programmable		72	69			
ON	OFF	Pre-defined, gel battery	5.5A	70	68			
OFF	ON	Pre-defined, flooded battery	D.SA	67				
ON	ON	Pre-defined, AGM battery,LiFe04	efined, AGM battery,LiFe04 73					

2. Programmable charging curve

Charging Curve can be set via SBP-001 with computer

Step 1


Hardware configuration


Step	Action	Note
1	DIP S.W position 2 and 3 need to swith to "OFF" position	ON DIP
2	The pin7 and pin8(Jumper) of 14pins connector need to removed when using SBP-001	2 1 1 13 14 13
3	Communication cable of SBP#1 connected between NPB-450 of personal computer	



Step 2

Connect to software for setting





NPB-450 pin assigment:

Connector		Pin Assigment												
NPB-450 14pins connector (Connector Part No.:HRS DF11-14DS)	1	2	3	4	5	6	7	8	9	10	11	12	13	14
14 13	A1	A0	+3.3V	GND	Battery Full	Charger OK	Remote ON-OFF	+12Vaux	GND	-AUX	CANH	CANL	NTC (RTH+)	NTC (RTH-)

SBP-001 pin assigment:

Connector	Pin Assigment										
SBP-001 10 pins connector		1	2	3	4	5	6	7	8	9	10
(Connector Part No.:HRS DF11-10DS)	150	UART_RX	UART_TX	PMBUS_D	PMBUS_C	CANH	CANL	5V	GND	3.3V	GND

or equivalent




※ Function Description:

SBP-001 is a programmer, particularly for MEAN WELL's various programmable battery charger models to program the parameters of charging curves, such as the 2 or 3 stage selectable, <u>Constant current (CC)</u>, <u>tapper current(TC)</u>, <u>Constant voltage (CV)</u>, <u>float voltage (FV)</u>, <u>Charging time out</u> and so on, to accommodate the diversified battery specification in industry. With the design accounting for simplicity and convenience, users can easily configure MEAN WELL's programmable battery chargers with SBP-001 programmer and the computer; all of the setups are able to be finished easily by the means of the specific software. Note:(1) Tapper current(TC) default is 10%, can be fine tuned from 2% to 30% by SBP-001 with computer or CANBus Interface.

(2) Please contact MEAN WELL for more details.

Software Interface:



3. Auto Ranging for Charging (Default non-Auto ranging)

- ※ Function Description:
 - a. NPB-450 has built-in auto ranging mode.
 - (Note this mode is set to OFF by factory default and is suitable for lithium batteries with BMS only)
 - b. When operating in auto ranging mode, NPB-450 will automatically detect the voltage of battery that is connected and adjust charging voltage accordingly. It will not start charging unit appropriate battery voltage is detected.
 - c. While under auto ranging mode, NPB-450's built-in MCU will adjust charging voltage. There is no potentiometer for voltage adjustment on the front panel.
 - d. While under auto ranging mode, the charging current can be adjusted between 50~100%.

 (The charging current can not be adjusted via potentiometer while not operating in auto ranging mode)



% When using the auto ranging charging curve function, please pay attention to the following:



- (1) Default factory setting is OFF via DC output side DIP S.W, Follow steps A1~A6 below to enable the setting.
- (2) Auto ranging function should use together with Lithium batteries and BMS (Battery Management System).
- (3) Do not exceed the output voltage and current ranges as specified in the NPB-450 specifications (please refer to page 2).
- X Auto Ranging function by DIP S.W Setting (Please make sure that the battery is lithium battery and must be matched with BMS before using. Auto ranging function is prohibited for non-lithium battery)

Step	Action	Note
A1	Set DIP S.W all in the "OFF" position(Default).	2 第 4 (0) 2 第 4 (0) 3 第 4 (0)
A2	Applying AC main and swith on under remote OFF.	2 1 1 13 13 14 13
A3	Within 15 seconds , set DIP S.W, all in the "ON" position and all back in the "OFF" again.	ON 019
A4	The green LED flashes 3 times means the process is successfully done.	* * *
A5	Restart the NPB-450 to load smart charging curve setting. (AC input on/off or swith on/off on AC input side)	AC — INPUT — AC — INPUT or
A6	Pin 7 & 8 put on jumper.	2 1 14 2 13

※ Back to non-auto ranging as following:

Step	Action	Note
B1	All DIP switch for charging curve setting are switch to ON position before applying AC main.	2 2 3 4 5 5 F
B2	Applying AC main under remote OFF condition.	2 1 1 13 14 13
В3	Switch the DIP switch from all ON to all OFF, and then again, back to all ON in 15 seconds.	ON DIP
B4	If LED flashes in GREEN for 3 times, it means the setting is succeeded.	* * *
B5	Remote ON the unit, and it's now back to factory setting.	14 13




4. Auto Derating function

X Covered by over temperature protection, auto de-rating function works under operation either in charging curve (2 or 3 stage) or under control by communication protocol(CANBus).

T₁(Typ.): Maximum ambient temperature of 100% output current.

T2(Typ.): T1+5 $^{\circ}$ C .



5.CANBus communication interface

CANBus 2.0B version, Can control, setting and monitoring that including output charging voltage, output charging current, internal temperature and DC output ON/OFF......and so on, please refer to the <u>user manual</u> for more details.



CANBus commend list

Command Code	Command Name	Transaction Type	# of data Bytes	Description
0x0000	OPERATION	R/W	1	ON/OFF control
0x0020	VOUT_SET	R/W	2	Output voltage setting (format: value, F=0.01)
0x0030	IOUT_SET	R/W	2	Output current setting (format: value, F=0.01)
0x0040	FAULT_STATUS	R	2	Abnormal status
0x0050	READ_VIN (NPB-450/750 Does not support)	R	2	Input voltage read value (format: value, F=0.1)
0x0060	READ_VOUT	R	2	Output voltage read value (format: value, F=0.01)
0x0061	READ_IOUT	R	2	Output current read value (format: value, F=0.01)
0x0062	READ_ TEMPERATURE_1	R	2	Internal ambient temperature (format: value, F=0.1)
0x0080	MFR_ID_B0B5	R	6	Manufacturer's name
0x0081	MFR_ID_B6B11	R	6	Manufacturer's name



Command Code	Command Name	Transaction Type	# of data Bytes	Description
0x0082	MFR_MODEL_B0B5	R	6	Manufacturer's model name
0x0083	MFR_MODEL_B6B11	R	6	Manufacturer's model name
0x0084	MFR_REVISION_B0B5	R	6	Firmware revision
0x0085	MFR_LOCATION_B0B2	R/W	3	Manufacturer's factory location
0x0086	MFR_DATE_B0B5	R/W	6	Manufacturer date
0x0087	MFR_SERIAL_B0B5	R/W	6	Product serial number
0x0088	MFR_SERIAL_B6B11	R/W	6	Product serial number
0x00B0	CURVE_CC	R/W	2	Constant current setting of charge curve (format: value, F=0.01)
0x00B1	CURVE_CV	R/W	2	Constant voltage setting of charge curve (format: value, F=0.01)
0x00B2	CURVE_FV	R/W	2	Floating voltage setting of charge curve (format: value, F=0.01)
0x00B3	CURVE_TC	R/W	2	Taper current setting value of charging curve (format: value, F=0.01)
0x00B4	CURVE_CONFIG	R/W	2	Configuration setting of charge curve
0x00B5	CURVE_CC_TIMEOUT	R/W	2	CC charge timeout setting of charging curve
0x00B6	CURVE_CV_TIMEOUT	R/W	2	CV charge timeout setting of charging curve
0x00B7	CURVE_FV_TIMEOUT	R/W	2	FV charge timeout setting of charging curve
0x00B8	CHG_STATUS	R	2	Charging status reporting
0x00C0	SCALING_FACTOR	R	2	Scaling ratio
0x00C1	SYSTEM_STATUS	R	2	System status
0x00C2	SYSTEM_CONFIG	R/W	2	System configuration

6.Charger OK Signal

Charger OK signal is a TTL level signal.

The maximum sourcing current is 10 mA.

Between Charger OK (pin 6) and GND-AUX (pin 9 & 10)	Charging Status	
"High": 4.5 ~ 5.5V	Work normally	
"Low" : -0.5 ~ 0.5V	Failure or protection function activated	





7.Battery Full Signal

Battery full signal is a TTL level signal.

The maximum sourcing current is 10mA.

Between Battery Full (pin 5) and GND-AUX (pin 9 & 10)	Status	LED indication
"High": 4.5 ~ 5.5V	Battery Full	Green
"Low": -0.5 ~ 0.5V	Charging	Orange



8.Remote ON-OFF Control

The NPB-450 can be turned ON/OFF by using the "Remote Control" function.

Between Remote ON-OFF (pin 7) and +12Vaux (pin 8)	Status
S.W Short (pin 7 = 10.8 ~ 13.2V)	ON (Default)
S.W Open (pin 7 = -0.5 ~ 0.5V)	OFF

※ The charger is shipped, by factory default, with Remote ON-OFF(pin 7) and +12Vaux (pin 8) shorted by connector.



9. Temperature compensation (3 stage only)

Temperature compensation function to prolong battery life for lead-acid batteries. Temperature compensation range is $0 \sim 40^{\circ} \mathrm{C}$.

The battery temperature sensor comes along with the charger can be connected to the unit to allow temperature compensation of the charging voltage. If the sensor is not used, the charger works normally.




10. DC Output Side LED Indicators & Corresponding Signal at Function Pins

LED	Description
Green	Float (stage 3) or Battery full
Orange	Charging (stage 1 or stage 2)
	Auto ranging for charging
Red	Abnormal status (OTP, OVP, Short circuit, Reverse polarity, Charging timeout.)
	The LED will flash with the red light when the internal temperature reaches 95°C; under this condition, the unit still
Theu (Flashling)	operates normally without entering OTP. (In the meantime, an alarm signal will be sent out through the CANBus interface.)



■ Mechanical Specification

※ Intelligent Battery Charger model



₩ DIP S.W

	1	2	3	Description
1	OFF: 3 stage	OFF	OFF	Default, programmable
1 2 3 OFF ON		ON	OFF	Pre-defined, Gel battery
	ON: 2 stage	OFF	ON	Pre-defined, flooded battery
		ON	ON	Pre-defined, AGM battery, LiFe04

$\frak{\%}$ Control Pin No. Assignment : HRS DF11-14DS or equivalent



Mating Housing	HRS DF11-14DS or equivalent
Terminal	HRS DF11-**SC or equivalent

Connector Pin No. Assignment: HRS DF11-14DS or equivalent

Confidence in the Assignment . The Bi 11-14-Do of equivalent				
Pin No.	Assignment	Mating Housing	Terminal	
1	A1			
2	A0			
3	+3.3V			
4	GND(Signal)			
5	Battery Full	HRS DF11-14DS or equivalent	HRS DF11-**SC or equivalent	
6	Charger OK			
7	Remote ON-OFF			
8	+12Vaux			
9,10	GND-AUX			
11	CANH			
12	CANL			
13	NTC(RTH+)			
14	NTC(RTH-)			

※ LED Status Table

LED Indicator	Status
Green	Float stage (stage 3) or full charged
Orange	Charging (stage 1 or stage 2)
Orange (Flashing)	Charging with auto ranging function
Red	Abnormal (OTP, OVP, short circuit, reverse polarity, time out)
Red (Flashing)	Unit over heated internally

450W High Reliable Ultra Wide Output Range Intelligent Battery Charger


Pin No.	Function	Description		
1	A1	CANBus interface address line(A1). Referenced to GND(Signal) Pin4.(Note.1)		
2	A0	ANBus interface address line(A0). Referenced to GND(Signal) Pin4.(Note.1)		
3	+3.3V	+3.3V voltage output, referance to GND(pin 4).		
4	GND(Signal)	CANBus interface address lines GND.		
5	Battery Full	Battery Full Signal, referenced to GND-AUX(Pin 9 & 10). The Signal is a TTL level signal. The maximum sourcing current is 10mA and only for output. (Note.2) Low $(-0.5 \sim 0.5 \text{V})$: When the battery is charging. High $(4.5 \sim 5.5 \text{V})$: When the battery is full.		
Charger OK Signal, referenced to GND-AUX(Pin 9 & 10). The Signal is a TTL level signal. The maximum sourcing current is 10mA and only for output.(No. Low (-0.5 ~ 0.5V): When the charger fails or the protect function is activating. High (4.5 ~ 5.5V): When the charger is working properly.		The Signal is a TTL level signal. The maximum sourcing current is 10mA and only for output. (Note.2) Low $(-0.5 \sim 0.5 \text{V})$: When the charger fails or the protect function is activating.		
7	Remote ON-OFF Remote ON-OFF Remote Charger ON/OFF Function. The charger can turn the output ON/OFF by dry contact between Remote ON-OFF and +12V-AUX.(Note.2) Short (10.8 ~ 13.2V): Charger ON; Open (-0.5 ~ 0.5V): Charger OFF; The maximum input voltage is 13.2V.			
8	+12Vaux It is controlled by the Remote ON-OFF control.			
9,10	GND-AUX	The signal return is isolated from the output terminal. (+V & -V)		
11	CANH	For CANBus model: Data line used in CANBus interface. (Note.2).		
12	CANL	For CANBus model: Data line used in CANBus interface. (Note.2).		
13	NTC(RTH+)	Temperature sensor(NTC, 5KOhm) comes along with the charger can be connected to the unit to allow temperature		
14	NTC(RTH-)	compensation of the charging voltage for lead-acid batteries. Temperature compensation range is $0 \sim 40^{\circ}\text{C}$ (3 stage only).		


 $Note 1: Non-isolated \ signal, \ referenced \ to \ [GND (signal)].$

Note2: Isolated signal, referenced to GND-AUX

■ Accessory List

 $\frak{\%}$ NTC Sensor and Remote Control mating along with NPB-450 (Standard accessory)









$\frak{\%}$ Carry handle (Optional accessory, battery charger and pull handle should be ordered seperately)

MW's Order No.		Item	Quantity
	1	Handle	1
DS-Carry Handle	2	Foot pad	4
	3	Screw	2

1 Handle



2 Foot pad



■ INSTALLATION MANUAL

Please refer to: http://www.meanwell.com/manual.html